

## **Mountain Lakes District Water Committee Report for June 2017**

This report covers the activities during June and the monthly meeting of July 7th.

Status: Draft as of 7/13/17 – Reviewed as of – 7/17/17 - Approved as of.

### **Mountain Lakes District Water Committee Meeting of 7/6/17**

Meeting was held from 8:02 AM to 8:40 AM. Attendees: Bob Long, Don Drew, Ken King, and Ed Rajsteter

#### **Water System Update:**

The water system is operating normally and production is about 40 thousand gallons per day which is normal for the summer time.

#### **Incident Reports:**

The gravel well pump failed. We ordered two of them so we will always have one in reserve. Don responded to an early morning call for a water issue on Valley road. The homeowner made the repair and the service was turned back on. We had a Low Level alarm from the Chambers due to a power issue. This was resolved.

The large rainfall on July 1<sup>st</sup> caused debris to build up on the intake drain that maintains the upper lake level. This raised the level of the upper lake which activated the spillway and flooded the beach and parking area. The debris was removed and the level quickly went back to normal. The spillway activation was reported to the state. Everything was dried up in time for the 4<sup>th</sup> of July

#### **Water Meters:**

We have determined the supplier for the meters. The first meter in the distribution network will be part of the Bear Road project.

#### **Bear Road Project:**

All of the material needed for the project has been delivered to Horne Excavating. The project will probably not start until the Fall in order to minimize the impact on the homes, most of which are not active at that time.

#### **Master Plan:**

A Public Hearing of the latest version of the updated Master Plan will be held on Saturday August 12<sup>th</sup> following the 9:00 AM Commissioners Meeting at the Lodge. An online copy will be made available prior to that meeting.

#### **Lower Dam Project:**

The state will be doing an inspection of both the lower dam and the spillway. Now that we have access to the spillway, we will complete some of the changes that were planned but never implemented. When they do this inspection, we will also have them look at the connection between the upper lake and the lower lake to see when we will have to reconstruct this system.

**Nobis Engineering – Water Sourcing** The state has approved funding for projects to try pumping out the well with MTBe issues as well as a ground penetrating radar analysis. This is now underway.

We approved the May minutes