

Mountain Lakes District Water Committee Report for August 2018

This report covers the activities during August and the monthly meeting of September 6th.

Status: Draft as of 9/19/2018 – Reviewed as of 9/26/2018.

Mountain Lakes District Water Committee Meeting of 9/6/2018.

Meeting was held from 8:06 AM to 8:37 AM. Attendees: Bob Long, Ken King, Ed Rajsteter and Mark Johanson

Water System Update: Current water usage is about 20-25,000 GPD. This is back to normal for this time of the year.

Incident Reports:

Found a water break on Belknap. The repair has been completed. It was in the exact location that Pybum and sons had located and marked for us.

SCADA is up and running again, had a possible lightning strike near the Chambers. Added surge protection to the line

Bear Road Project:

This is on hold until the water flow on Kearsarge is determined. We may be able to get some support from the state in this area.

Lower Dam and Spillway Project:

Bob and Don met with D&K rep, Jeff Tucker. We need to set up an appointment with the state to approve the final plan

Nobis Engineering – Water Sourcing:

The sight is now clear from any MTBE. We need to do some additional pumping to determine the capacity of the well. It is not clear if the state will supply any additional funding

SCADA system:

The system is installed and up and running. We have decided to use the Omni Meter from EJ Prescott for the pump house meters.

New Meters for the Chambers:

There is more to this than just the two meters. Don is still working on this.

Valve Repair at Hanover and King:

Completed. Job well done by Paige Contracting.

New Business:

Standby power for pump house – Paul Hatch will continue to work with Don on applying for the grants.

New bid for a Water Repair contractor will be advertised as of Oct 15.